



Standard 6" min trench undercut and backfill with granular crushed rock or GPIWA approved clean sand. Stabilize with mechanical compaction to 95% max. Density per T-180

ADDITIONAL UNDERCUT AND CRUSHED ROCK BEDDING FOUNDATION (USED ONLY WHEN DIRECTED BY OWNERS REP. TO REMOVE UNSTABLE MATERIAL FROM TRENCH FOUNDATION.) STABILIZE CRUSHED ROCK BACKFILL IN 6" LIFTS WITH MECHANICAL COMPACTION PER T-180

① LOCATOR TAPE PER GPIWA specifications

TRENCH CROSS SECTION	SCALE: N.T.S.
	DATE:
	CHK:
	DWG #: C-5