



NOTES:

1. FLUSHING DETAIL TO BE USED ON WATER LINES > 8" DIAMETER.
2. FLUSHING PIPE SHALL BE THE SAME DIAMETER AS WATER MAIN.
3. AFTER FLUSHING HAS BEEN COMPLETED, CONTRACTOR SHALL INSTALL BLOW OFF PER STANDARD DETAIL.
4. CONTRACTOR SHALL PROVIDE ADEQUATE DRAINAGE FOR FLUSHED WATER.
5. SEPERATE CONCRETE FROM BOLTS WITH 1 LAYER POLY-FILM.

WATER MAIN FLUSHING DETAIL	SCALE: N.T.S.
	DATE:
	CHK:
	DWG #: W-9